

PAS, PDS Performance Notes

- Data obtained from tests conducted in accordance with ANSI / ASHRAE Standard 70-1991. Actual performance, with flexible duct inlet, may vary in the field. See the Engineering Guidelines section of this catalog for additional information.

- Throw values given are for terminal velocities of 150, 100 and 50 fpm and for isothermal conditions.
- For an explanation of catalog throw data, see the section, Engineering Guidelines.
- NC values based on octave band 2 to 7 sound power levels minus a room absorption of 10 dB.

- Each NC value represents the noise criteria curve that will not be exceeded by the sound pressure in any of the octave bands, 2 through 7, with a room absorption of 10 dB, re 10⁻¹² watts.
- Dash (-) in space denotes an NC value of less than 10.
- All pressures are given in inches of water.
- To obtain static pressure, subtract the velocity pressure from the total pressure.

PAR, PXP, PMR, PXP-DR, PDR Performance Data

PAR, PXP, PMR • Flush Face • Return; PXP-DR, PDR • Drop Face • Return

	Neck Size	Neck Vel, fpm	300	400	500	600	700	800	1000	1200	1400
		Vp, in. Wg	0.01	0.01	0.02	0.02	0.03	0.04	0.06	0.09	0.12
		Ps (-), in. Wg	0.03	0.06	0.09	0.13	0.17	0.23	0.36	0.51	0.70
12 x 12 Face	6 Dia. *	Flow Rate, cfm	59	78	98	118	137	157	196	235	275
		Room NC	-	-	-	14	18	21	27	32	36
		6 x 6 Neck *	Flow Rate, cfm	75	100	125	150	175	200	250	300
		Room NC	-	-	-	12	17	21	24	30	35
24 x 24 Face	10 x 10 Neck	Flow Rate, cfm	208	278	347	417	486	556	694	833	972
		Room NC	15	23	29	33	37	41	47	51	55
		Neck Size	Neck Vel, fpm	300	400	500	600	700	800	1000	1200
		Vp, in. Wg	0.01	0.01	0.02	0.02	0.03	0.04	0.06	0.09	0.12
		Ps (-), in. Wg	0.03	0.06	0.09	0.13	0.17	0.24	0.37	0.54	0.73
24 x 24 Face	6 Dia. *	Flow Rate, cfm	59	78	98	118	137	157	196	235	275
		Room NC	-	-	-	13	17	20	26	31	34
		6 x 6 Neck *	Flow Rate, cfm	75	100	125	150	175	200	250	300
		Room NC	-	-	-	14	18	21	27	32	35
24 x 24 Face	8 Dia. *	Flow Rate, cfm	105	140	174	209	244	279	349	419	488
		Room NC	-	-	-	13	17	21	24	30	35
		8 x 8 Neck *	Flow Rate, cfm	133	178	222	267	311	356	444	533
		Room NC	-	-	-	14	18	22	25	31	36
24 x 24 Face	10 Dia. *	Flow Rate, cfm	164	218	273	327	382	436	545	654	763
		Room NC	-	-	-	16	20	24	27	33	38
		10 x 10 Neck *	Flow Rate, cfm	208	278	347	417	486	556	694	833
		Room NC	-	11	17	21	25	28	34	39	42
24 x 24 Face	12 Dia. *	Flow Rate, cfm	235	314	392	471	549	628	785	942	1099
		Room NC	-	12	17	22	26	29	34	39	43
		12 x 12 Neck *	Flow Rate, cfm	300	400	500	600	700	800	1000	1200
		Room NC	-	14	20	24	28	31	37	42	45
24 x 24 Face	14 Dia. *	Flow Rate, cfm	320	427	534	641	748	855	1068	1282	1495
		Room NC	-	15	21	25	29	32	38	43	46
		15 x 15 Neck *	Flow Rate, cfm	469	625	781	938	1094	1250	1563	1875
		Room NC	-	16	22	26	30	33	39	44	47
24 x 24 Face	18 Dia. *	Flow Rate, cfm	419	558	698	837	977	1116	1395	1674	1953
		Room NC	11	18	24	28	32	35	41	46	49
		18 x 18 Neck *	Flow Rate, cfm	675	900	1125	1350	1575	1800	2250	2700
		Room NC	11	18	24	28	32	36	41	46	49
24 x 24 Face	22 x 22 Neck	Flow Rate, cfm	1008	1344	1681	2017	2353	2689	3361	4033	4706
		Room NC	13	20	26	30	34	37	43	47	51
		Other Sizes	Neck Size	Neck Vel, fpm	300	400	500	600	700	800	1000
		Vp, in. Wg	0.01	0.01	0.02	0.02	0.03	0.04	0.06	0.09	0.12
		Ps (-), in. Wg	0.03	0.06	0.09	0.13	0.17	0.23	0.36	0.51	0.70
Other Sizes	10 x 22 (12 x 24 Face)	Flow Rate, cfm	458	611	764	917	1069	1222	1528	1833	2139
		Room NC	-	-	-	14	18	21	27	32	36
		14 x 14 (16 x 16 Face)	Flow Rate, cfm	408	544	681	817	953	1089	1361	1633
		Room NC	-	-	12	17	21	24	30	35	39
Other Sizes	18 x 18 (20 x 20 Face)	Flow Rate, cfm	675	900	1125	1350	1575	1800	2250	2700	3150
		Room NC	-	11	17	22	26	29	35	40	44
		22 x 46 (24 x 48 Face)	Flow Rate, cfm	2108	2811	3514	4217	4919	5622	7028	8433
		Room NC	12	20	25	30	34	38	43	48	52

PAR, PXP, PMR, PXP-DR, PDR Performance Notes

- * Supply unit with deflectors removed.

- Static pressures are negative, in inches of water, measured per ANSI/ASHRAE Standard 70-91.
- Noise Criteria (NC) based on a room absorption of 10 dB, re 10⁻¹² watts, measured per ANSI/ASHRAE Standard 70-91.

- These products have been tested per ANSI/ASHRAE Standard 70-91. Actual performance, with flexible duct inlet, may vary in the field.
- See the section, Engineering Guidelines for additional information.